



October 25, 1994

11:53

10/27/94

Ms. Verneta Simon
On-Scene Coordinator
US Environmental Protection Agency
77 W. Jackson Blvd., HSE-5J
Chicago, IL 60604

RE: Lindsay Light II Site, 316 E. Illinois St., Chicago, IL

Dear Ms. Simon:

During the course of the investigation of the above-referenced site, decontamination fluids were generated from the washing of the down-hole gamma logging equipment and the soil sampling equipment. That water was stored in a 55-gallon drum, locked in an on-site trailer pending analysis.

We have received results of the analysis of this water which we have attached to this letter. No evidence of contamination from the radioactive material is indicated in these results.

Upon receipt of your concurrence, it is our intention to discharge this water into the on-site storm sewer, which drains to the Chicago City combined storm/sanitary sewer system. Inasmuch as the water was originally potable water from the public water supply, and analysis shows no evidence of impairment, it is our opinion that this disposal method will not result in any adverse environmental impacts.

Please advise us at your earliest convenience of the USEPA's response to this request.

Regards,

STS CONSULTANTS, LTD.

Richard G. Berggreen

Principal Geologist

RGB:BB1:seb

cc: Charles Gardner, CDCT

Vince Oleskiewicz, Baker & McKenzie

\$T\$ Consultants Ltd. Consulting Engineers



TELEDYNE BROWN ENGINEERING

Environmental Services Midwest Laboratory 700 Landwehr Road • Northbrook, IL 60062-2310 Phone (708) 564-0700 • Fax (708) 564-4517

| Mr. Steve Newlin | LABORATORY REPORT NO.: | 8100-3184 |
|---------------------|------------------------|---------------|
| STS Consultants LTD | DATE: | 10-10-94 |
| 1415 Lake Cook Road | SAMPLES RECEIVED: | 09-29-94 |
| Deerfield, IL 60015 | TYPE OF REPORT: | COMPLETE |
| - | PURCHASE ORDER NO.: | STS *27313-ZK |

Dear Mr. Newlin:

Below are the results of the analyses for gross alpha and gross beta in two (2) water samples collected September 27, 1994.

| Sample | Lab | Concentration | n (pCi/L) | |
|------------------|----------------------|-----------------|---------------------|----------|
| Description | Code | gross α | gross β | <u> </u> |
| Drum-1 Drum-2 | SPW-5184 SPW-5185 | 1.2±1.0 <0.9 | 6.1±1.3 12.9±0.7 | |

The error given is the probable counting error at 95% confidence level. Less than values are based on 3 sigma counting error for background samples.

Sincerely,

Tony Coorlim, Special Projects

TC:lsd

10/27/94

Calculations for Lindsay Light II Site Water Samples Generated from Site Investigation Activity - May 1994 for STS Project No. 27313-ZH

STS CONSULTANTS

Minimum Detectable Activity (MDA) for Counting System 1)

$$MDA = \underbrace{\frac{4.65 \sigma}{E \times Vol \times 2.22 E6}}$$

$$MDA = \frac{4.65 (0.067)}{(0.3419)(100)(2.22E6)}$$

$$MDA = 4.1 E-09 \mu Ci/ml$$

2) Water Sample Concentration Calculations for Individual Samples (from Sample Counting Sheet)

Average = 4.1 E-09 μ Ci/ml or MDA

Average = $3.45 \pm 0.65 \text{ E}-09 \,\mu\text{Ci/ml}$

Average = 1.0 ± 0.53 E-08 μ Ci/ml

Average = 4.1 E-09 μ Ci/ml or MDA

3) Overall Average Concentrations and Standard Deviation

Drum 1 - 3.78
$$\pm$$
 0.65 E-09 μ Ci/ml or

Drum 2 -
$$7.76 \pm 5.67$$
 E-09 μ Ci/ml

The 10 CFR 20, Table 2, Column 2 concentration limit for Thorium-232 in water releases is 3 E-08 μ Ci/ml. The monthly average limit for releases to sanitary sewers is 3 E-07 μ Ci/ml. The above analyses show that the water generated from the on-site work is essentially non-radioactive and can be free released as necessary.

| | SAMPLE COUNTING SHEET | | | | | | | | | | |
|-------------------------|---|---------------------|------------------------|-----------------|--------------|------------|---------|------------|--|--|--|
| | M.J.W. JOB NO. 142-94-073-01 DATE 9/3-14/94 TIME 1500 | | | | | | | | | | |
| | LOCATION MOW Office INSTRUMENT MODEL Ludley 1000 | | | | | | | | | | |
| | INSTRUMENT SERIAL NO. 64322 PROBE MOD./SER. Luden 43-10 054854 | | | | | | | | | | |
| | CALIBRATION DATE 4/30/44 CHECKED BY 640 EFFICIENY (%) 1534 = 35.17% | | | | | | | | | | |
| | HIGH VOLTAGE SETTING 900 V THRESHOLD N/M WINDOW N/M | | | | | | | | | | |
| 9/13BAC | 9/3BACKGROUND COUNTS 7 COUNTING TIME 10 BKG RATE 0.7 CAN | | | | | | | | | | |
| SMEAR TYPE ALPHA B/G | | | COUNTING TIME (MIN) | GROSS COUNTS | GROSS CPM | NET CPM | DPM | uCi/ ml | | | |
| 9/13 | | BACKGRUND | 100 | 74 | 0.74 | | _ | | | | |
| 1/14 | | BACKGAOUND | 100 | 6/ | 0.61 | | | | | | |
| <u></u> | 9//3 | DAM 1,#1 | 1 | 1 | 1,0 | 0.32 | 0.91 | 4.1E-09 | | | |
| / | 11 | DRUM 1. #Z | 1 | 1 | 1.0 | 0.32 | 0.91 | 4.1E-09 | | | |
| ~ | 74 | DRUM Z, #1 | ! | 1 | 1.0 | 0.32 | 0.91 | 4.1E-09 | | | |
| / | 11 | DAWN 2, # 2 | 1 | 1 | 1.0 | 0.32 | 0.91 | 4.1E-09 | | | |
| / | 9/14 | Drum 1, #1 | 10 | 10 | 1.0 | 0.32 | 0.91 | 4.1E-09 | | | |
| ~ | 11 | DRum 1, 42 | 10 | 9 | 0.9 | 0.22 | 0.63 | 2.8E-09 | | | |
| <u> </u> | le | DRum 2, # 1 | 10 | 20 | 2.0 | 1.32 | 3.75 | 1.7E-08 | | | |
| <u>/</u> | t į | Dam 2, #2 | 10 | 10 | 1.0 | 0.32 | 0.91 | 4.1E-09 | | | |
| | 11 | | 1 | 7151 | 7151 | 7150 | 33.2% | ok | | | |
| ✓ | ŧţ | & Same BRUMZ, ±1 | 100 | 142 | 1.42 | 0.74 | 2.1 | 9.5E-09 | | | |
| | | \ | | | | | | | | | |
| | | | | | | | | <u> </u> | | | |
| · | | | | | | | | | | | |
| | ` | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | \ | | | | | |
| | | | | | | | | | | | |
| | | | | V | | | | | | | |
| ECHNI | ECHNICIAN: LA Locay VERIFICATION: James V Wuromohi DATE 9/15/94 | | | | | | | | | | |
| | σ | | | | | | | | | | |